Pleasants Power Station

Compliance Assurance Monitoring (CAM) Summary Report

Reporting Period

July 1, 2017 through December 31, 2017

Company:

Allegheny Energy Supply Pleasants Power Station

Address:

#1 Power Station Boulevard Willow Island, WV 26134

Unit Description: Coal Fired Generating Facility

Pollutant:

Particulate Matter

Emission Limit: 312.25 lbs/hr per Unit

Emissions Data Summary	Unit 1	Unit 2
Total source hours of operation (hr)	3,125	3,876
Duration (hr) of excess emissions in reporting period due to:		
a.) Startup/shutdown	0	0
b.) Control equipment problems	0	0
c.) Process problems	0	0
d.) Other known problems	0	0
e.) Unknown excess emissions cause	0	0
Total duration of excess emission (hr)	0	0
3. Excess emissions duration (%)	0.0%	0.0%
Monitoring downtime (hr) in reporting period due to:		
a.) Monitoring equipment malfunction	0.0	10.5
b.) Non-monitoring equipment malfunction	0	0
c.) Quality assurance calibration	0	0
d.) Other known cause	0	0
e.) Unknown causes	0	0
2. Total CEMS downtime (hr)	0.0	10.5
3. Cems downtime (%)	0.0%	0.3%

Compliance Assurance Monitoring (CAM)

Detail Report

Reporting Period

July 1, 2017 through December 31, 2017

Company:

Allegheny Energy Supply Pleasants Power Station

Address:

#1 Power Station Boulevard Willow Island, WV 26134

Unit Description:

Coal Fired Generating Facility

Pollutant:

PM

Emission Limit: 312.25 lb/hr per Unit

Unit 1 Excursions

Date	Starting Time	Ending Time	Reason	Action(s) Taken
none in reporting period				

Unit 2 Excursions

Date	Starting Time	Ending Time	Reason	Action(s) Taken
none in reporting period				

Unit 1 Monitoring Downtime

Date	Starting Time	Ending Time	Total Hours	Reason	Action(s) Taken
none in reporting period					

0:00

Unit 2 Monitoring Downtime

Date	Starting Time	Ending Time	Total Hours	Reason	Action(s) Taken
10/4/2017	3:30	7:30	4.00	Loss of communication	Communication restored
10/19/201 - 10/20/2017	23:45	6:15	6.50	Loss of communication	Communication restored